

CHAPTER Comm 61 to 65 APPENDIX A

The material contained in this appendix is for clarification purposes only and is numbered to correspond to the number of the rule as it appears in the text of the code.

**A-61.03 (4)(b) Lower thresholds for municipalities with preexisting stricter sprinkler ordinances.**

Section 101.14 (4m) (d) and (e), Stats, provides the following thresholds above which fire sprinkler protection or 2-hour fire-resistance can be required by a municipality with a preexisting stricter sprinkler ordinance.

Class of Construction	Total Floor Area Within Individual Dwelling Units	Number of Units	Total Floor Area of Nondwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, community rooms, laundry rooms, pools, etc.)
Type IA	8,000 sq ft	8 units	12,000 sq ft
Type IB			10,000 sq ft
Type IIA			8,000 sq ft
Type IIB			5,600 sq ft
Type III			
Type IV			
Type VA			
Type VB	4,800 sq ft		

The department, based on ordinances forwarded by municipalities (and checked by Safety and Buildings staff for conformance with the preexisting sprinkler ordinance criteria) believes the following municipalities have preexisting stricter sprinkler ordinances:

- |            |                 |            |                 |
|------------|-----------------|------------|-----------------|
| Appleton   | Greenfield      | Muskego    | Shorewood Hills |
| Brookfield | Madison         | New Berlin | Sussex          |
| Franklin   | Menomonee Falls | Oak Creek  | West Allis      |
| Greendale  | Monona          | Racine     | West Bend       |

SECTION 8. Chapter Comm 50 to 64 Appendix C is renumbered Comm 61 to 65 Appendix B.

SECTION 9. Chapters Comm 66, 69 and 73 are repealed.

\*\*\*\*\*

EFFECTIVE DATE

Pursuant to s. 227.22 (2) (b), Stats., these rules shall take effect on July 1, 2002.

\*\*\*\*\*