

Chapter NR 665

APPENDIX III

EPA INTERIM PRIMARY DRINKING WATER STANDARDS

Parameter	Maximum level (mg/L)
Arsenic.....	0.05
Barium.....	1.0
Cadmium.....	0.01
Chromium.....	0.05
Fluoride.....	1.4-2.4
Lead.....	0.05
Mercury.....	0.002
Nitrate (as N).....	10
Selenium.....	0.01
Silver.....	0.05
Endrin.....	0.0002
Lindane.....	0.004
Methoxychlor.....	0.1
Toxaphene.....	0.005
2,4-D.....	0.1
2,4,5-TP Silvex.....	0.01
Radium.....	5 pCi/L
Gross Alpha.....	15 pCi/L
Gross Beta.....	4 millirem/yr
Turbidity.....	1/TU
Coliform Bacteria.....	1/100 ml

Note: Turbidity is applicable only to surface water supplies.